

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL338		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner ERIC GUNDERSON						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address W10615 PRINDLE RD						Town of ALMA						W10615			
City BLACK FIVER FALLS						State WI		Zip Code 54615				Street Address or Road Name and Number W10615 PRINDLE RD			
County Jackson		Co. Permit #		Notification # 10054716401		Completed 11-17-2025		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) RUSH, JON A				Lic. # 5837		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.41134 °N -90.84303 °W				Method Code GPS008	
Address RUSH WELL DRLG LLC N7570 ODEEN ROAD BLACK RIVER FALLS WI 54615				Well Plan Approval #				NE SE		Section 3		Township 22 N		Range 4 W	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 0				2. Well Type New Well					
Reason for replaced or reconstructed well ?															
3. Well serves 1 # of CABIN				Hicap Well ? No				Construction Type Drilled							
Private, potable Drillhole				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
10		Surface		58		No Rotary - Mud Circulation				No					
6		58		140		No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						Yes Cable-tool Bit 10in. dia...				No					
						No Dual Rotary				No					
						Yes Temp. Outer Casing 10in. dia									
						Yes Removed? 26depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T	Q	X		T-TAN/BROWN Q-CAVING X-SAND & CLAY				Surface		12					
T	S	N		T-TAN/BROWN S-SOFT/LOOSE N-SANDSTONE				12		26					
T	M	N		T-TAN/BROWN M-MEDIUM N-SANDSTONE				26		58					
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE				58		140					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL, 18.97#/FT, ASTMA53B, LEAVITTE, WELDED0				Surface		58							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT GROUT				Surface		58		24							
9. Static Water Level															
92 ft. below ground surface															
10. Pump Test															
Pumping level 96 ft. below surface															
Pumping at 10 GP M for 1 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
16 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
JAR				Lic # 5837		Date Signed 01-15-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									
JAR				5837		01-15-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		70

Comment: SAMPLE WILL BE DELAYED

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	02/06/2026	

Created On: 01-15-2026

Updated On: 02-06-2026

Review Status: APPROVED