Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL338

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	ERIC GUNDERSON
Phone #	
Mailing Address	W10615 PRINDLE RD
City	BLACK FIVER FALLS
State	WI
Zip Code	54615
County	Jackson
Co. Permit #	
Notification #	10054716401
Completed	11-17-2025
Well Constructor (Business Name)	RUSH, JON A
Lic. #	5837
Facility ID # (Public Wells)	
Address	RUSH WELL DRLG LLC N7570 ODEEN ROAD BLACK RIVER FALLS WI 54615
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	2.5

1. Well Location

Town of ALMA	
Fire # (if avail.)	W10615
Street Address or Road Name and Number	W10615 PRINDLE RD
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	44.41134 °N -90.84303 °W
Method Code	GPS008
NE SE or Govt Lot #	
Section	3
Township	22 N
Range	4 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of CABIN

Private,potable Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	58
6	58	140

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 26depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	X		T-TAN/BROWN Q-CAVING X-SAND & CLAY	Surface	12
T	S	N		T-TAN/BROWN S-SOFT/LOOSE N-SANDSTONE	12	26
T	M	N		T-TAN/BROWN M-MEDIUM N-SANDSTONE	26	58
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	58	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 18.97#/FT, ASTMA53B, LEAVITTE, WELDED0	Surface	58
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

92 ft. below ground surface

10. Pump Test

Pumping level 96 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	58	24

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAR	5837	01-15-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JAR	5837	01-15-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		70

Comment: SAMPLE WILL BE DELAYED

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	02/06/2026	

Created On: 01-15-2026 Updated On: 10-15-2026 Review Status: APPROVED