

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL344		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner SWENINK, STEVE						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 114 ROCK AVE						Town of KICKAPOO						6958	
City VIROQUA						State WI		Zip Code 54665				Street Address or Road Name and Number HWY 14	
County Vernon		Co. Permit #		Notification # 9948560301		Completed 01-14-2026		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) KOUBA DRILLING LLC				Lic. # 8148		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.4791 °N -90.8274 °W				Method Code SCR002	
Address 325 S PARK ST REEDSBURG WI 53959				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 35 12 N 4 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1									
3. Well serves 1 # of HOME/SHOP Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology				
10 Surface 82.5			Yes Rotary - Mud Circulation Yes			Yes			Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)				
6 82.5 180			Yes Rotary - Air Yes			Yes			C G C-CLAY G-W/GRAVEL/STONES Surface 9				
			No Rotary - Air & Foam No			No			S H C S-SOFT/LOOSE H-SHALE C-CLAYEY 9 26				
			No Drill-Through Casing Hammer			No			E M H E-GREEN M-MEDIUM H-SHALE 26 49				
			No Reverse Rotary			No			G H H G-GRAY H-HARD/FIRM H-SHALE 49 115				
			No Cable-tool Bit ___ in. dia... No			No			U H H U-BLUE H-HARD/FIRM H-SHALE 115 180				
			No Dual Rotary No			No							
			No Temp. Outer Casing ___ in. dia			No							
			No Removed? ___ depth ft. (If NO explain on back side)			No							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is	
6		WHEATLAND STEEL, WELDED, .280 WALL, ASTM A53B, DRIVE SHOE				Surface		82.5		38 ft. below ground surface		18 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes	
										Pumping level 160 ft. below surface		Disinfected ? Yes	
										Pumping at 15 GP M for 1 Hrs.		Capped ? Yes	
										Pumping Method ? Airlift			
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No	
Method TREMIE PIPE - PUMPED												Filled & Sealed Well(s) as needed? No	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT GROUT		Surface		82.5		33 S				13. Constructor / Supervisory Driller		Lic #	
										MLK		8149	
										Date Signed		01-15-2026	
										Drill Rig Operator		Lic or Reg #	
										AS		7291	
										Date Signed		01-14-2026	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Septic or Holding, or POWTS Tank	>	25

Comment:

CREW ENCOUNTERED FRACTURE IN SOFT SHALE AT 9 TO 26 FT WITH A BIG SPRING AT 17 FT THAT REQUIRED 22 BAGS OF HYDRATED 3/8" CHIPS TO SEAL OFF IN ORDER TO CONTINUED TO CEMENT GROUT TO SURFACE.

Created On: 01-15-2026

Updated On: 02-09-2026

Review Status: APPROVED