

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL368		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner ROLOF TOM				Phone # (608)843-1007		1. Well Location				Fire # (if avail.)	
Mailing Address 8243 MAIN ST						Town of PRESQUE ISLE				7820	
City PRESQUE ISLE				State WI		Zip Code 54557				Street Address or Road Name and Number BOXBURGER	
County Vilas		Co. Permit #		Notification # 10093662001		Completed 01-05-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) BINZ, STEVE E				Lic. # 3570		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.225 °N -89.6775 °W		Method Code GPS008	
Address BINZ BROTHERS WELL DRILLING 6400 ODANAH RD HURLEY WI 54534-9736				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 7 43 N 7 E		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 0		of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable Borehole		Reason for replaced or reconstructed well ?		Heat Exchange ___ # of drillholes	
Hicap Property ? No				Hicap Potable ? No		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes	
6		Surface		57		No Rotary - Mud Circulation		No		Z Z-CLAY & GRAVEL Surface 40	
						No Rotary - Air		No		G G-GRAVEL/STONES 40 50	
						No Rotary - Air & Foam		No		Y Y-SAND & GRAVEL 50 57	
						No Drill-Through Casing Hammer					
						No Reverse Rotary					
						No Cable-tool Bit ___ in. dia...		No			
						No Dual Rotary		No			
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Type, Caving/Noncaving, Color, Hardness, etc...											
From (ft.) To (ft.)											
11. Well Is											
14 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
Lic # 3570											
Date Signed 01-16-2026											
Drill Rig Operator											
Lic or Reg # 7323											
Date Signed 01-16-2026											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		60	POWTS dispersal component (soil absorption unit or mound)		90

Comment:

Created On: 01-16-2026

Updated On: 02-09-2026

Review Status: APPROVED