Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL368

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROLOF TOM	Phone #: (608)843-1007
Mailing Address: 8243 MAIN ST	
City: PRESQUE ISLE	State: WI — Zip Code: 54557
County: Vilas	Co. Permit #:
Notification #: 10093662001	Completed: 01-05-2026
Well Constructor (Business Name): BINZ, STEVE E	Lic. #: 3570
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: BINZ BROTHERS WELL DRILLING 6400 ODANAH RD HURLEY WI 54534-9736	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 3	

1. Well Location

Town of PRESQUE ISLE				Fire # (if avail.): 7820
Street Address or Road Name and Number: BOXBURGER				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 46.225 °N -89.6775 °W				Method Code: GPS008
NW NW or Govt Lot #	Section: 7	Township: 43 N	Range: 7 E	

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Borehole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	57

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Z	Z-CLAY & GRAVEL	Surface	40
G	G-GRAVEL/STONES	40	50
Y	Y-SAND & GRAVEL	50	57

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 LBS/FT WHEATLAND WELDED	Surface	54
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	SS ALLOY MACHINE 15 SLOT	54	57

7. Grout or Other Sealing Material

Method MOUNDED GRANULAR BENTONITE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	54	5 S

9. Static Water Level

35 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
SB	3570	01-16-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
SB	7323	01-16-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		60	POWTS dispersal component (soil absorption unit or mound)		90

Comment:

Created On: 01-16-2026 Updated On: 10-15-2026 Review Status: APPROVED