Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL373

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CHASE, EMMA	Phone #
Mailing Address: N1057 COUNTY ROAD NZ	
City: NESHKORO	State: WI — Zip Code: 54960
County: Waushara	Co. Permit #: — Notification #: 10123822301 — Completed: 01-12-2026
Well Constructor (Business Name): JENKS, TIMOTHY J	Lic. #: 4458 — Facility ID # (Public Wells):
Address: JENKS WELL DRILLING W4849 ASPEN CT. WILD ROSE WI 54984	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 10

1. Well Location

Town of MARION	Fire # (if avail.): N1057
Street Address or Road Name and Number: COUNTY ROAD NZ	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.01771 °N -89.16471 °W	Method Code: SCR002
NW SW or Govt Lot #:	Section: 23 — Township: 18 N — Range: 11 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: FAILED 2" WELL

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	71

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y	C	T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL C-CLAYEY	Surface	33
T	Q	Z	G	T-TAN/BROWN Q-CAVING Z-CLAY & GRAVEL G-W/GRAVEL/STONES	33	52
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	52	71

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A53B P.E WELDED 18.97#/FT 1780 HYDRO	Surface	67
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	15 SLOT SS	67	71

9. Static Water Level

38 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 20 GP M for 1.5 Hrs.

Pumping Method ? Other

11. Well Is

15 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TJ	4458	01-16-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Septic or Holding, or POWTS Tank		45

Comment:

Created On: 01-16-2026 Updated On: 02-09-2026 Review Status: APPROVED