

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL405		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner CLARK PATRICK & CHRISTINE				Phone # (262)412-2839		1. Well Location				Fire # (if avail.)	
Mailing Address W257 N7598 AUTUMN WAY						Village of LISBON					
City SUSSEX				State WI		Zip Code 53089					
County Waukesha		Co. Permit # Wisconsin		Notification # 10134376801		Completed 04-28-2026		Subdivision Name OCTOBER FIELDS		Lot # 20	
Well Constructor (Business Name) 4-D WATER WELL & PUMP SERVICE LLC				Lic. # 8157		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.1233 °N -88.2599 °W		Method Code SCR002	
Address N82 W28160 MARSHALL DR HARTLAND WI 53029				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 28 8 N 19 E					
Hicap Permanent Well #				Common Well #		Specific Capacity 0		2. Well Type New Well			
3. Well serves 1 # of HOME				Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?			
Private, potable				Hicap Potable ? No		Construction Type Drilled					
Heat Exchange ___ # of drillholes											
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock			
6		Surface		57		No Rotary - Mud Circulation		No			
5		57		60		No Rotary - Air		No			
						No Rotary - Air & Foam		No			
						Yes Drill-Through Casing Hammer					
						No Reverse Rotary					
						No Cable-tool Bit ___ in. dia...		No			
						No Dual Rotary		No			
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
T Z		T-TAN/BROWN Z-CLAY & GRAVEL				Surface		48			
T Y		T-TAN/BROWN Y-SAND & GRAVEL				48		60			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6		6 INCH WELDED NEW STEEL PLAIN END .A53 ASTM .280 X 20 MARIUCCI LEAVITT				Surface		57			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
5		SS 25 SLOT WITH PACKER AND BOTTOM PLATE				57		60			
7. Grout or Other Sealing Material											
Method MOUND											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE		Surface				1 S					
9. Static Water Level											
31 ft. below ground surface											
10. Pump Test											
Pumping level 40 ft. below surface											
Pumping at 25 GP M for 2 Hrs.											
Pumping Method ? Airlift											
11. Well Is											
18 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
Lic #		Date Signed									
DW 6377		04-29-2026									
Drill Rig Operator		Lic or Reg #		Date Signed							
LM 7824		04-28-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		59	POWTS dispersal component (soil absorption unit or mound)		66

Comment:

Created On: 01-21-2026

Updated On: 05-29-2026

Review Status: APPROVED