Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL405

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: CLARK PATRICK & CHRISTINE	Phone #: (262)412-2839
Mailing Address: W257 N7598 AUTUMN WAY	
City: SUSSEX	State: WI — Zip Code: 53089
County: Waukesha	Co. Permit #: Wisconsin — Notification #: 10134376801 — Completed: 04-28-2026
Well Constructor (Business Name): 4-D WATER WELL & PUMP SERVICE LLC	Lic. #: 8157 — Facility ID # (Public Wells):
Address: N82 W28160 MARSHALL DR HARTLAND WI 53029	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2.8

1. Well Location

Village of LISBON — Fire # (if avail.):

Street Address or Road Name and Number: W257 N5798 AUTUMN WAY

Subdivision Name	Lot #	Block #
OCTOBER FIELDS	20	

Latitude / Longitude in Decimal Degree (DD): 43.1233 °N -88.2599 °W — Method Code: SCR002

NW SW or Govt Lot #	Section	Township	Range
	28	8 N	19 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	57
5	57	60

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Z	T-TAN/BROWN Z-CLAY & GRAVEL	Surface	48
T Y	T-TAN/BROWN Y-SAND & GRAVEL	48	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6 INCH WELDED NEW STEEL PLAIN END .A53 ASTM .280 X 20 MARIUCCI LEAVITT	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS 25 SLOT WITH PACKER AND BOTTOM PLATE	57	60

7. Grout or Other Sealing Material

Method MOUND

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level

31 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 25 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DW	6377	04-29-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
LM	7824	04-28-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		59	POWTS dispersal component (soil absorption unit or mound)		66

Comment:

Created On: 01-21-2026 Updated On: 10-15-2026 Review Status: APPROVED