Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL453

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KRAHN, JEFF			Phone #
Mailing Address: PO BOX 536			
City: WAUTOMA	State: WI	Zip Code: 54982	
County: Waushara	Co. Permit #:	Notification #: 10133718701	Completed: 01-18-2026

Well Constructor (Business Name): JENKS, TIMOTHY J	Lic. #: 4458	Facility ID # (Public Wells):	
Address: JENKS WELL DRILLING W4849 ASPEN CT. WILD ROSE WI 54984		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.2	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of MARION

Fire # (if avail.): W7036

Street Address or Road Name and Number: SILVERCRYST RD.

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.05948 °N -89.23467 °W	SCR002

NW SE or Govt Lot #	Section	Township	Range
	6	18 N	11 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
FAILED 2" WELL

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	58

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	Surface	25
T	Q	S	M	T-TAN/BROWN Q-CAVING S-SAND M-SILTY	25	52
T	W	S		T-TAN/BROWN W-WATER BEARING S-SAND	52	58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	MARUICHI LEAVITT P.E. WELDED .237 WALL	Surface	54
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	10 SLOT SS	54	58

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level
19 ft. below ground surface

10. Pump Test
Pumping level 28 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ? Other

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TJ	4458	01-22-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		45	Sewer - Building Sanitary		12

Comment:

Created On: 01-28-2026 Updated On: 02-18-2026 Review Status: APPROVED