Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL484

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WALKER INVESTMENT PROPERTIES	Phone #
Mailing Address: 20799 FLAGHILL AVE	
City: TOMAH	State: WI — Zip Code: 54660
County: Monroe	Co. Permit #:
Notification #: 10098463801	Completed: 02-11-2026
Well Constructor (Business Name): NELSONS PLBG & ELEC INC	Lic. #: 42
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 25269 HWY 12 TOMAH WI 54660-5174	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.3	

1. Well Location

Town of GREENFIELD	Fire # (if avail.): 20799
Street Address or Road Name and Number: FLAGHILL AVE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.9976 °N -90.5624 °W	Method Code: GPS008
NW NE or Govt Lot #:	Section: 36 — Township: 18 N — Range: 2 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	158
6	158	235

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 7depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		C-CLAY	Surface	6
T	S	H		T-TAN/BROWN S-SOFT/LOOSE H-SHALE	6	125
	M	N		M-MEDIUM N-SANDSTONE	125	190
	Q	N		Q-CAVING N-SANDSTONE	190	235

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND, STEEL PE WELD 18.97LB A#53	Surface	158
4	FLUSH JOINT PVC LINER	20	200
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	PRE PACKED JOHNSON SCREEN	200	210

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND NEAT CEMENT	Surface	158	50 S

9. Static Water Level

160 ft. below ground surface

10. Pump Test

Pumping level 190 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

N/A

Filled & Sealed Well(s) as needed? No

N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
MN	3799	02-18-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Landfill	>	1200

Comment:

Created On: 02-03-2026 Updated On: 03-12-2026 Review Status: APPROVED