

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL484		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner WALKER INVESTMENT PROPERTIES						Phone #													
Mailing Address 20799 FLAGHILL AVE						1. Well Location						Fire # (if avail.)							
City TOMAH						State WI		Zip Code 54660				Town of GREENFIELD		20799					
Street Address or Road Name and Number FLAGHILL AVE																			
County Monroe		Co. Permit #		Notification # 10098463801		Completed 02-11-2026		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) NELSONS PLBG & ELEC INC				Lic. # 42		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9976 °N -90.5624 °W				Method Code GPS008					
Address 25269 HWY 12 TOMAH WI 54660-5174				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 36 18 N 2 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3															
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)				
10 Surface 158			No Rotary - Mud Circulation No								T S H C-CLAY		Surface 6						
6 158 235			No Rotary - Air No								T S H T-TAN/BROWN S-SOFT/LOOSE H-SHALE		6 125						
			Yes Rotary - Air & Foam Yes								M N M-MEDIUM N-SANDSTONE		125 190						
			No Drill-Through Casing Hammer Reverse Rotary								Q N Q-CAVING N-SANDSTONE		190 235						
			No Cable-tool Bit ___ in. dia... No																
			No Dual Rotary No																
			Yes Temp. Outer Casing 10in. dia																
			Yes Removed? 7depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		160 ft. below ground surface				24 in. above grade					
6		WHEATLAND, STEEL PE WELD 18.97LB A#53				Surface		158		10. Pump Test				Developed ? Yes					
4		FLUSH JOINT PVC LINER				20		200		Pumping level 190 ft. below surface				Disinfected ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 10 GP M for 1 Hrs.				Capped ? Yes					
4		PRE PACKED JOHNSON SCREEN				200		210		Pumping Method ? Test Pump									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No					
Method TREMIE PIPE - PUMPED														N/A					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No									
PORTLAND NEAT CEMENT				Surface		158		50 S		N/A									
13. Constructor / Supervisory Driller														Lic #		Date Signed			
MN														3799		02-18-2026			
Drill Rig Operator														Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Landfill	>	1200

Comment:

Created On: 02-03-2026

Updated On: 03-12-2026

Review Status: APPROVED