Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL493

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WITTENBERG,DAVID	Phone #
Mailing Address: 206 OAK KNOLL BLVD	
City: MANKATO	State: MN Zip Code: 56001
County: Polk	Co. Permit #:
Notification #: 10094843201	Completed: 12-04-2025
Well Constructor (Business Name): HISCHER, DANIEL D	Lic. #: 175
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: KIRK HISCHER WELL DRILLING 2449 ST RD 35 LUCK WI 54853-9803	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2.9	

1. Well Location

Town of MILLTOWN	Fire # (if avail.): 1852
Street Address or Road Name and Number: KEMAH PK LN	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 45.47741 °N -92.44603 °W	Method Code: GPS008
SW NW or Govt Lot #:	Section: 35 Township: 35 N Range: 17 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	58

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	C	Z	T-TAN/BROWN V-NON-CAVING C-CLAY Z-W/COBBLES/BOULDERS	Surface	15
T	H	G	C	T-TAN/BROWN H-HARD/FIRM G-GRAVEL/STONES C-CLAYEY	15	51
T	H	G		T-TAN/BROWN H-HARD/FIRM G-GRAVEL/STONES	51	58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	STEEL 11#FT A53 .237X4.5X18 IPSCO USA T&C	Surface	54
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	S. STEEL V SLOT .012	53	58

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 22 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DDH	175	12-08-2025
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KDH	7488	12-08-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		48	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 02-03-2026 Updated On: 02-23-2026 Review Status: APPROVED