Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL495

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: POUCHER,JACK			Phone #
Mailing Address: PO BOX 28			
City: BALSAM LAKE	State: WI	Zip Code: 54810	
County: Polk	Co. Permit #:	Notification #: 10122593201	Completed: 01-14-2026

Well Constructor (Business Name): HISCHER, DANIEL D	Lic. #: 175	Facility ID # (Public Wells):	
Address: KIRK HISCHER WELL DRILLING 2449 ST RD 35 LUCK WI 54853-9803		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 4	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of BALSAM LAKE

Fire # (if avail.): 1220

Street Address or Road Name and Number: 158TH AVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.43647 °N	-92.41167 °W			GPS008
NE NE or Govt Lot #	Section: 13	Township: 34 N	Range: 17 W	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	48

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	H	C	Z	T-TAN/BROWN H-HARD/FIRM C-CLAY Z-W/COBBLES/BOULDERS	Surface	25
T	H	G		T-TAN/BROWN H-HARD/FIRM G-GRAVEL/STONES	25	48

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	STEEL 11#FT A53 .237X4.5X18 IPSCO USA T&C	Surface	44
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	V SLOT S.STEEL .15	43	48

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 23 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DDH	175	01-16-2026
Drill Rig Operator	Lic or Reg #	Date Signed
KDH	7488	01-16-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		158

Type	Qualifier	Distance
Building Drain - Sanitary		28
Septic or Holding, or POWTS Tank		98

Comment: WATER TEST WILL BE LATE, NO ELECTRICITY ONSITE

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	02/24/2026	

Created On: 02-06-2026 Updated On: 10-15-2026 Review Status: APPROVED