

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL495		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner POUCHER,JACK				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address PO BOX 28				City BALSAM LAKE		State WI		Zip Code 54810		Town of BALSAM LAKE	
County Polk				Co. Permit #		Notification # 10122593201		Completed 01-14-2026		Street Address or Road Name and Number 158TH AVE	
Well Constructor (Business Name) HISCHER, DANIEL D				Lic. # 175		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.43647 °N -92.41167 °W		Method Code GPS008	
Address KIRK HISCHER WELL DRILLING 2449 ST RD 35 LUCK WI 54853-9803				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 13 34 N 17 W		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 0		of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?		Construction Type Drilled			
Private,potable				Hicap Property ? No		Hicap Potable ? No		Heat Exchange ___ # of drillholes			
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
4		Surface		48		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... T H C Z T-TAN/BROWN H-HARD/FIRM C-CLAY Z- W/COBBLES/BOULDERS T H G T-TAN/BROWN H-HARD/FIRM G-GRAVEL/STONES	
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is	
4		STEEL 11#FT A53 .237X4.5X18 IPSCO USA T&C				Surface		44		16 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test	
4		V SLOT S.STEEL .15				43		48		Pumping level 23 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ? Test Pump	
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No			
GRANULAR BENTONITE		Surface				1 S		Filled & Sealed Well(s) as needed? No			
13. Constructor / Supervisory Driller											
DDH		Lic #		Date Signed		175		01-16-2026		13. Constructor / Supervisory Driller	
Drill Rig Operator		Lic or Reg #		Date Signed		7488		01-16-2026		13. Constructor / Supervisory Driller	
KDH										13. Constructor / Supervisory Driller	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		158	Building Drain - Sanitary		28
			Septic or Holding, or POWTS Tank		98

Comment: WATER TEST WILL BE LATE, NO ELECTRICITY ONSITE

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	02/24/2026	

Created On: 02-06-2026**Updated On:** 02-24-2026**Review Status:** APPROVED