Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL512

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LIVINGSTON, TRUE & MEGAN	Phone #: (608)576-9998
Mailing Address: 525 W SOUTH ST 1	
City: STOUGHTON	State: WI — Zip Code: 53589
County: Dane	Co. Permit #: 00001 — Notification #: 10130103001 — Completed: 02-03-2026
Well Constructor (Business Name): BLOYER WELL & PUMP CO INC	Lic. #: 87 — Facility ID # (Public Wells):
Address: 14312 FULMAR DR SOUTH BELOIT IL 61080-2399	Well Plan Approval #: Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: 01 — Specific Capacity: 10

1. Well Location

Town of CHRISTIANA	Fire # (if avail.): 1646
Street Address or Road Name and Number: 1646 HILLSIDE ROAD CAMBRIDGE WI 53523	
Subdivision Name: CSM 11701	Lot #: 2 — Block #:
Latitude / Longitude in Decimal Degree (DD): 42.93786 °N -89.04182 °W	Method Code: SCR002
SW SE or Govt Lot #:	Section: 35 — Township: 6 N — Range: 12 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	42
6	42	120

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	Yes
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		X		T-TAN/BROWN X-SAND & CLAY	Surface	41
T		N		T-TAN/BROWN N-SANDSTONE	41	112
R		N	H	R-RED N-SANDSTONE H-SHALEY	112	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLK T&C STEEL .280 #19.45 ASTM A53 WHEATLAND USA	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

45 ft. below ground surface

10. Pump Test

Pumping level 48 ft. below surface

Pumping at 30 GP M for 1.5 Hrs.

Pumping Method ? Airlift

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CETCO QUICK GROUT	Surface	42	5 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
AES	6639	02-04-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		78	POWTS dispersal component (soil absorption unit or mound)		115

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	03/19/2026	WAITING ON TO BUILDER TO CONNECT PLUMBING

Created On: 02-04-2026 Updated On: 10-15-2026 Review Status: APPROVED