Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL550

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NELSON ROGER	Phone #
Mailing Address: 1985 IROQUOIS CT	
City: OSHKOSH	State: WI Zip Code: 54901

County	Co. Permit #	Notification #	Completed
Waushara		10130391401	02-06-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
VETTER, WILLIAM	6351	

Address: 1036 TOWNSEND RD
WAUPACA WI 54981

Hicap Permanent Well #	Common Well #	Specific Capacity
		5

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of ROSE	Fire # (if avail.) N6955

Street Address or Road Name and Number: N6955 LAKE CIRCLE DRIVE

Subdivision Name	Lot #	Block #
	2	

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.22961 °N -89.31571 °W	SCR002

SW SE or Govt Lot #	Section	Township	Range
	4	20 N	10 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	140

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	Surface	120
T	W	S		T-TAN/BROWN W-WATER BEARING S-SAND	120	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL WELDED JOINT WHEATLAND 18.97PDS PER FT 6.625X280A53GRB	Surface	136
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	SS.12 SLOT JOHNSON	136	140

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	8	2 S

9. Static Water Level
89 ft. below ground surface

10. Pump Test
Pumping level 91 ft. below surface
Pumping at 10 GP M for 48 Hrs.
Pumping Method ? Test Pump

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WV	6351	02-06-2026
Drill Rig Operator	Lic or Reg #	Date Signed
GV	8784	02-06-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		50	POWTS dispersal component (soil absorption unit or mound)		60

Comment: PUMP TO BE INSTALLED BY PLUMBER

Created On: 02-06-2026 Updated On: 02-24-2026 Review Status: APPROVED