

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL587		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner COLGAN CUSTOM HOMES - 390 CANDY LN						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 390 CANDY LN						Town of KINNICKINNIC						390			
City RIVER FALLS						State WI		Zip Code 54022				Street Address or Road Name and Number CANDY LN			
County St. Croix		Co. Permit #		Notification # 10143074701		Completed 02-27-2026		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) PELKE PLBG & WELL DRLG INC				Lic. # 535		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.91807 °N -92.59668 °W				Method Code GPS008	
Address N6298 STATE HWY 25 DURAND WI 54736-9105				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 17 28 N 18 W				2. Well Type New Well					
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7		Reason for replaced or reconstructed well ?				Construction Type Drilled					
3. Well serves 1 # of HOME						Hicap Well ? No		Private, potable						Hicap Property ? No	
Heat Exchange ___ # of drillholes						Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		240		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No Yes Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
C		C-CLAY				Surface		37							
S		S-SAND				37		45							
L		L-LIMESTONE/DOLOMITE				45		75							
N		N-SANDSTONE				75		205							
L		L-LIMESTONE/DOLOMITE				205		240							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		18.97 LBS WHEATLAND USA A-53 GR-B				Surface		45							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface											
9. Static Water Level															
170 ft. below ground surface															
10. Pump Test															
Pumping level 200 ft. below surface															
Pumping at 20 GP M for 1 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
16 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
BP				8725		03-03-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									
BP				8725		03-03-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 02-10-2026

Updated On: 04-06-2026

Review Status: APPROVED