Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL587

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: COLGAN CUSTOM HOMES - 390 CANDY LN	Phone #
Mailing Address: 390 CANDY LN	
City: RIVER FALLS	State: WI — Zip Code: 54022
County: St. Croix	Co. Permit #: — Notification #: 10143074701 — Completed: 02-27-2026
Well Constructor (Business Name): PELKE PLBG & WELL DRLG INC	Lic. #: 535 — Facility ID # (Public Wells): — Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Address: N6298 STATE HWY 25, DURAND WI 54736-9105	
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 0.7	

1. Well Location

Town of KINNICKINNIC				Fire # (if avail.): 390
Street Address or Road Name and Number: CANDY LN				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 44.91807 °N -92.59668 °W				Method Code: GPS008
NW or Govt Lot #	NW	Section: 17	Township: 28 N	Range: 18 W

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	240

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
Yes	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		C-CLAY	Surface	37
		S		S-SAND	37	45
		L		L-LIMESTONE/DOLOMITE	45	75
		N		N-SANDSTONE	75	205
		L		L-LIMESTONE/DOLOMITE	205	240

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97 LBS WHEATLAND USA A-53 GR-B	Surface	45
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
170 ft. below ground surface

10. Pump Test
Pumping level 200 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
BP	8725	03-03-2026
Drill Rig Operator	Lic or Reg #	Date Signed
BP	8725	03-03-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 02-10-2026 Updated On: 04-06-2026 Review Status: APPROVED