Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: ACL629

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: OHLINGER, SEAN	Phone #
Mailing Address: 4449 N. MALDEN ST.	
City: CHICAGO	State: IL — Zip Code: 60640
County: Waushara	Co. Permit #: — Notification #: 10139481001 — Completed: 02-07-2026
Well Constructor (Business Name): JENKS, TIMOTHY J	Lic. #: 4458 — Facility ID # (Public Wells):
Address: JENKS WELL DRILLING W4849 ASPEN CT. WILD ROSE WI 54984	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 4.2

1. Well Location

Town of MOUNT MORRIS	Fire # (if avail.): N3968
Street Address or Road Name and Number: LAKESIDE LANE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.1194 °N -89.20506 °W	Method Code: SCR002
NW SW or Govt Lot #:	Section: 16 — Township: 19 N — Range: 11 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	69

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	Surface	28
T	N	S		T-TAN/BROWN N-FINE S-SAND	28	42
T	N	S	C	T-TAN/BROWN N-FINE S-SAND C-CLAYEY	42	48
T	V	C		T-TAN/BROWN V-NON-CAVING C-CLAY	48	55
T	N	S	C	T-TAN/BROWN N-FINE S-SAND C-CLAYEY	55	60
T	W	S		T-TAN/BROWN W-WATER BEARING S-SAND	60	69

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A53B P.E WELDED 18.97#/FT 1780 HYDRO	Surface	65
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	10 SLOT SS	65	69

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 16 ft. below surface
Pumping at 25 GP M for 1 Hrs.
Pumping Method ? Other

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TJ	4458	02-09-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		75	POWTS dispersal component (soil absorption unit or mound)		60
			Septic or Holding, or POWTS Tank		30

Comment:

Created On: 02-11-2026 Updated On: 03-04-2026 Review Status: APPROVED