

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL629		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner OHLINGER, SEAN						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 4449 N. MALDEN ST.								Town of MOUNT MORRIS				N3968									
City CHICAGO						State IL		Zip Code 60640				Street Address or Road Name and Number LAKESIDE LANE									
County Waushara		Co. Permit #		Notification # 10139481001		Completed 02-07-2026		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) JENKS, TIMOTHY J				Lic. # 4458		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.1194 °N -89.20506 °W				Method Code SCR002							
Address JENKS WELL DRILLING W4849 ASPEN CT. WILD ROSE WI 54984				Well Plan Approval #				NW SW		Section 16		Township 19 N		Range 11 E							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 4.2				2. Well Type New Well											
3. Well serves 1 # of HOME				Hicap Well ? No				of previous unique well #				constructed in									
Private, potable				Hicap Property ? No				Reason for replaced or reconstructed well ?													
Heat Exchange ___ # of drillholes				Hicap Potable ? No				Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method												8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		69		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)								T Q Y T N S T N S C T V C T N S C T W S		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL T-TAN/BROWN N-FINE S-SAND T-TAN/BROWN N-FINE S-SAND C-CLAYEY T-TAN/BROWN V-NON-CAVING C-CLAY T-TAN/BROWN N-FINE S-SAND C-CLAYEY T-TAN/BROWN W-WATER BEARING S-SAND		Surface 28 42 48 48 55 55 60 60 69			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		10 ft. below ground surface				16 in. above grade							
6		WHEATLAND A53B P.E WELDED 18.97#/FT 1780 HYDRO				Surface		65		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 16 ft. below surface				Disinfected ? Yes							
6		10 SLOT SS				65		69		Pumping at 25 GP M for 1 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material												Pumping Method ? Other									
Method MOUNDED												12. Notified Owner of need to fill & seal ?				No					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				No							
GRANULAR BENTONITE				Surface				1 S													
13. Constructor / Supervisory Driller												Lic #		Date Signed							
TJ												4458		02-09-2026							
Drill Rig Operator												Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)		75	POWTS dispersal component (soil absorption unit or mound)		60
			Septic or Holding, or POWTS Tank		30

Comment:

Created On: 02-11-2026

Updated On: 03-04-2026

Review Status: APPROVED