Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL647

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FRAZER, STEVE	Phone #
Mailing Address: 4833 160TH ST	
City: CHIPPEWA FALLS	State: WI — Zip Code: 54729
County: Chippewa	Co. Permit #: 20260017 — Notification #: 10145718901 — Completed: 03-23-2026
Well Constructor (Business Name): OLSON KEN WELL DRLG & PUMP SER INC	Lic. #: 215 — Facility ID # (Public Wells)
Address: 10224 20TH AVE EAU CLAIRE WI 54703-0288	Well Plan Approval # — Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity: 4

1. Well Location

Town of LAFAYETTE

Fire # (if avail.)

Street Address or Road Name and Number: 5961 163RD ST

Subdivision Name	Lot #	Block #
FRAZER II	19	

Latitude / Longitude in Decimal Degree (DD): 44.9292 °N -91.3441 °W — Method Code: SCR002

NW or Govt Lot #	NW	Section	Township	Range
		10	28 N	8 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	42

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y	C	Y-SAND & GRAVEL C-CLAYEY	Surface	28
T	M	S		T-TAN/BROWN M-MEDIUM S-SAND	28	42

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, NEW BLACK T&C; ASTM A53; .280 WALL; 19.45#/FT; WHEATLAND	Surface	39
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	JOHNSON STAINLESS 10 SLOT	39	42

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
KDO	6208	03-23-2026
Drill Rig Operator	Lic or Reg #	Date Signed
TR	9109	03-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	50	POWTS dispersal component (soil absorption unit or mound)		66
			Landfill		540

Comment:

Variance ID	Variance or Exception Type	Date	Reason
78120	Landfill Variance	03/17/2026	ENTIRE SUBDIVISION WITHIN DISTANCE TO CLOSED LANDFILL

Created On: 02-12-2026 Updated On: 04-13-2026 Review Status: APPROVED