

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL675		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner HERRICK,KEVIN					Phone #			1. Well Location				Fire # (if avail.)					
Mailing Address E2800 PHYLANE								Town of SPRING GREEN				E2800					
City SPRING GREEN					State WI		Zip Code 53588		Street Address or Road Name and Number				E2800 PHYLANE RD				
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #			
Sauk				10142029101		02-07-2026											
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code					
RODAKMAKER, ROBERT J				6664				43.1787 °N -90.1785 °W				SCR002					
Address WATERMAKER WELL DRLG&WATR SYS LLC 8055 FORTIER RD ARENA WI 53503				Well Plan Approval #		SW SE		Section		Township		Range					
				Approval Date (mm-dd-yyyy)		or Govt Lot #		7		8 N		3 E					
Hicap Permanent Well #			Common Well #			Specific Capacity			2. Well Type New Well								
									of previous unique well #				constructed in				
									Reason for replaced or reconstructed well ?								
3. Well serves 1 # of HOME				Hicap Well ?		No		Construction Type				Driven Point					
Private,potable				Hicap Property ?		No											
Heat Exchange ___ # of drillholes				Hicap Potable ?		No											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
1.25		Surface		32		No Rotary - Mud Circulation		No		Y Q S S		Y-YELLOW Q-CAVING S-SAND S-SANDY		Surface		32	
						No Rotary - Air		No									
						No Rotary - Air & Foam		No									
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		12 ft. below ground surface		15 in. above grade					
1.25		WHEATLAND A53 THREADED AND COUPLED GALVANIZED PIPE				Surface		28		10. Pump Test		Developed ? Yes					
										Pumping level ___ ft. below surface		Disinfected ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at ___ GP for ___ Hrs.		Capped ? Yes					
1.25		ALLOY STEEL 10 SLOT STAINLESS STEEL DRIVE POINT				28		32		Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?		No			
Method MOUNDED																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?		No					
GRANULAR BENTONITE				Surface		28		1 S									
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												BR				02-26-2026	
												Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	29	Building Drain - Sanitary	>	10
POWTS dispersal component (soil absorption unit or mound)	>	55	Sewer - Building Sanitary	>	14

Comment:

Created On: 02-13-2026

Updated On: 03-24-2026

Review Status: APPROVED