Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL675

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HERRICK,KEVIN	Phone #
Mailing Address: E2800 PHYLANE	
City: SPRING GREEN	State: WI — Zip Code: 53588
County: Sauk	Co. Permit #: — Notification #: 10142029101 — Completed: 02-07-2026
Well Constructor (Business Name): RODAMAKER, ROBERT J	Lic. #: 6664 — Facility ID # (Public Wells):
Address: WATERMAKER WELL DRLG&WATR SYS LLC 8055 FORTIER RD ARENA WI 53503	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity:

1. Well Location

Town of SPRING GREEN	Fire # (if avail.): E2800
Street Address or Road Name and Number: E2800 PHYLANE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.1787 °N -90.1785 °W	Method Code: SCR002
SW SE or Govt Lot #:	Section: 7 — Township: 8 N — Range: 3 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Driven Point

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
1.25	Surface	32

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Q	S	S	Y-YELLOW Q-CAVING S-SAND S-SANDY	Surface	32

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
1.25	WHEATLAND A53 THREADED AND COUPLED GALVANIZED PIPE	Surface	28
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	ALLOY STEEL 10 SLOT STAINLESS STEEL DRIVE POINT	28	32

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	28	1 S

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level _____ ft. below surface

Pumping at _____ GP for _____ Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
BR		02-26-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	29
POWTS dispersal component (soil absorption unit or mound)	>	55

Type	Qualifier	Distance
Building Drain - Sanitary	>	10
Sewer - Building Sanitary	>	14

Comment:

Created On: 02-13-2026 Updated On: 03-24-2026 Review Status: APPROVED