Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL685

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MAURER TRUST	Phone #
Mailing Address: 758 TERRA COTTA DR.	
City: NEENAH	State: WI — Zip Code: 54956
County: Washington	Co. Permit #: — Notification #: 10145258301 — Completed: 02-12-2026
Well Constructor (Business Name): BIERSACK, ROBERT K	Lic. #: 6413 — Facility ID # (Public Wells):
Address: BIERSACK WELL SERVICE W4502 ST RD 20 EAST TROY WI 53120	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 3

1. Well Location

Town of WEST BEND

Fire # (if avail.):

Street Address or Road Name and Number: 5910 N. LAKE DR.

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 43.4041 °N -88.2591 °W — Method Code: SCR002

NW SW or Govt Lot #: — Section: 20 — Township: 11 N — Range: 19 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: OLD WELL IN WAY OF NEW HOUSE

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	46

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y		Z		Y-YELLOW Z-CLAY & GRAVEL	Surface	23
G		X		G-GRAY X-SAND & CLAY	23	34
R		S		R-RED S-SAND	34	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NOVA STEEL ASTM A53B 18.97 PPF P/E	Surface	43
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	15 SLOT STAINLESS STEEL	43	46

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 25 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ? Other

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

TO BE DONE BY PUMP INSTALLER

Filled & Sealed Well(s) as needed? Yes

BY PUMP INSTALLER

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB	6413	02-13-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25

Comment:

Created On: 02-13-2026 Updated On: 08-05-2026 Review Status: APPROVED