Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL746

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FRAZER, STEVE			Phone #
Mailing Address: 4833 160TH ST			
City: CHIPPEWA FALLS	State: WI	Zip Code: 54729	
County: Chippewa	Co. Permit #: 20260016	Notification #: 10145717001	Completed: 03-23-2026

Well Constructor (Business Name): OLSON KEN WELL DRLG & PUMP SER INC	Lic. #: 215	Facility ID # (Public Wells)	
Address: 10224 20TH AVE EAU CLAIRE WI 54703-0288		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 3.3	

1. Well Location

Town of LAFAYETTE

Fire # (if avail.)

Street Address or Road Name and Number: 5981 162ND ST

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): 44.9298 °N -91.344 °W			Method Code: SCR002
SW SW or Govt Lot #	Section: 3	Township: 28 N	Range: 8 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	41

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		X	G	X-SAND & CLAY G-W/GRAVEL/STONES	Surface	35
		S	M	S-SAND M-SILTY	35	38
T	M	S		T-TAN/BROWN M-MEDIUM S-SAND	38	41

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, NEW BLACK T&C; ASTM A53; .280 WALL; 19.45#/FT; WHEATLAND	Surface	38
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	JOHNSON STAINLESS 10 SLOT	38	41

9. Static Water Level

24 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
KDO	6208	03-23-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TR	9109	03-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	50	POWTS dispersal component (soil absorption unit or mound)		63
			Landfill		760

Comment:

Variance ID	Variance or Exception Type	Date	Reason
78100	Landfill Variance	03/17/2026	ENTIRE SUBDIVISION WITHIN DISTANCE TO CLOSED LANDFILL

Created On: 02-18-2026 Updated On: 10-15-2026 Review Status: APPROVED