

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL746		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner FRAZER, STEVE						Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address 4833 160TH ST						Town of LAFAYETTE								
City CHIPPEWA FALLS						State WI		Zip Code 54729				Street Address or Road Name and Number 5981 162ND ST		
County Chippewa		Co. Permit # 20260016		Notification # 10145717001		Completed 03-23-2026		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) OLSON KEN WELL DRLG & PUMP SER INC				Lic. # 215		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.9298 °N -91.344 °W			Method Code SCR002	
Address 10224 20TH AVE EAU CLAIRE WI 54703-0288				Well Plan Approval #		SW SW		Section 3		Township 28 N		Range 8 W		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type New Well				of previous unique well # constructed in				
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled				
Private, potable				Hicap Property ? No										
Heat Exchange ___ # of drillholes				Hicap Potable ? No										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		41		No Rotary - Mud Circulation No								
						No Rotary - Air No								
						No Rotary - Air & Foam No								
						No Drill-Through Casing Hammer								
						No Reverse Rotary								
						No Cable-tool Bit ___ in. dia... No								
						No Dual Rotary No								
						No Temp. Outer Casing ___ in. dia								
						No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
		X G		X-SAND & CLAY G-W/GRAVEL/STONES				Surface		35				
		S M		S-SAND M-SILTY				35		38				
T M S				T-TAN/BROWN M-MEDIUM S-SAND				38		41				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		STEEL, NEW BLACK T&C; ASTM A53; .280 WALL; 19.45#/FT; WHEATLAND				Surface		38						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
5		JOHNSON STAINLESS 10 SLOT				38		41						
7. Grout or Other Sealing Material														
Method MOUNDED														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
GRANULAR BENTONITE				Surface										
9. Static Water Level														
24 ft. below ground surface														
10. Pump Test														
Pumping level 30 ft. below surface														
Pumping at 20 GP M for 2 Hrs.														
Pumping Method ? Test Pump														
11. Well Is														
18 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ? No														
Filled & Sealed Well(s) as needed? No														
13. Constructor / Supervisory Driller														
Lic #				Date Signed										
KDO				6208				03-23-2026						
Drill Rig Operator				Lic or Reg #				Date Signed						
TR				9109				03-23-2026						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)	>	50	POWTS dispersal component (soil absorption unit or mound)		63
			Landfill		760

Comment:

Variance ID	Variance or Exception Type	Date	Reason
78100	Landfill Variance	03/17/2026	ENTIRE SUBDIVISION WITHIN DISTANCE TO CLOSED LANDFILL

Created On: 02-18-2026

Updated On: 04-13-2026

Review Status: APPROVED