Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL757

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	BORTH NATHAN
Phone #	
Mailing Address	CABLE SUNSET RD
City	CABLE
State	WI
Zip Code	54821
County	Bayfield
Co. Permit #	
Notification #	10056702701
Completed	11-15-2025
Well Constructor (Business Name)	ANDERSON, PAUL R
Lic. #	4681
Facility ID # (Public Wells)	
Address	PAUL R ANDERSON WELL DRILLING 60995 WIBERG RD ASHLAND WI 54806
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	1

1. Well Location

Fire # (if avail.)	
Town of CABLE	
Street Address or Road Name and Number	CABLE SUNSET RD
Subdivision Name	
Lot #	
Block #	
Latitude / Longitude in Decimal Degree (DD)	46.2078 °N -91.301 °W
Method Code	GPS008
SW NW or Govt Lot #	
Section	18
Township	43 N
Range	7 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	6
4	6	80

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 4in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	S	S	T-TAN/BROWN V-NON-CAVING S-SAND S-SANDY	Surface	60
T	Q	S	S	T-TAN/BROWN Q-CAVING S-SAND S-SANDY	60	77
T	W	S	S	T-TAN/BROWN W-WATER BEARING S-SAND S-SANDY	77	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4.5	4"ID T&D ASTM A-53-B WEATLAND	Surface	77
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	10 SLOT SCREEN 4X2 KPACK	77	80

9. Static Water Level

60 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	6	4 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
PA	4681	02-18-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RH	8996	02-18-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	50

Comment:

Created On: 02-18-2026 Updated On: 10-15-2026 Review Status: APPROVED