

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL757		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner BORTH NATHAN						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address CABLE SUNSET RD						Town of CABLE															
City CABLE						State WI		Zip Code 54821													
County Bayfield		Co. Permit #		Notification # 10056702701		Completed 11-15-2025		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) ANDERSON, PAUL R				Lic. # 4681		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.2078 °N -91.301 °W				Method Code GPS008							
Address PAUL R ANDERSON WELL DRILLING 60995 WIBERG RD ASHLAND WI 54806				Well Plan Approval #				SW NW		Section 18		Township 43 N		Range 7 W							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #			Common Well #			Specific Capacity 0			2. Well Type New Well												
3. Well serves 1 # of HOME Private, potable Drillhole Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? Construction Type Drilled													
						Hicap Property ? No															
						Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		6		No Rotary - Mud Circulation				No		T V S S		T-TAN/BROWN V-NON-CAVING S-SAND S-SANDY		Surface		60			
4		6		80		No Rotary - Air				No		T Q S S		T-TAN/BROWN Q-CAVING S-SAND S-SANDY		60		77			
						No Rotary - Air & Foam				No		T W S S		T-TAN/BROWN W-WATER BEARING S-SAND S-SANDY		77		80			
						No Drill-Through Casing Hammer															
						No Reverse Rotary															
						Yes Cable-tool Bit 4in. dia...				No											
						No Dual Rotary				No											
						No Temp. Outer Casing ___ in. dia															
						No Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		60 ft. below ground surface				12 in. above grade							
4.5		4"ID T&D ASTM A-53-B WEATLAND				Surface		77		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 70 ft. below surface				Disinfected ? Yes							
2		10 SLOT SCREEN 4X2 KPACK				77		80		Pumping at 10 GP M for 2 Hrs.				Capped ? Yes							
										Pumping Method ? Test Pump											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No							
Method MOUNDED																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No											
GRANULAR BENTONITE				Surface		6		4 S													
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														PA		4681		02-18-2026			
														Drill Rig Operator		Lic or Reg #		Date Signed			
														RH		8996		02-18-2026			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	50

Comment:

Created On: 02-18-2026

Updated On: 03-17-2026

Review Status: APPROVED