

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL807		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner SCANDINAVIAN LOG				Phone # (715)561-5420		1. Well Location				Fire # (if avail.)	
Mailing Address 7020W US 2						Town of OMA				8316N	
City HURLEY				State WI Zip Code 54534		Street Address or Road Name and Number PARDEE LAKE RD WEST					
County Iron		Co. Permit #		Notification # 10130292101		Completed 02-13-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) BINZ, STEVE E				Lic. # 3570		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.2781 °N -89.9401 °W		Method Code GPS008	
Address BINZ BROTHERS WELL DRILLING 6400 ODANAH RD HURLEY WI 54534-9736				Well Plan Approval #		NE SW Section Township Range or Govt Lot # 24 44 N 4 E		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 1		Reason for replaced or reconstructed well ?			
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable Borehole		Hicap Property ? No		Construction Type Drilled	
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
6		Surface		39		No Rotary - Mud Circulation		No		Geology Codes	
						No Rotary - Air		No		Type, Caving/Noncaving, Color, Hardness, etc...	
						No Rotary - Air & Foam		No		From (ft.) To (ft.)	
						No Drill-Through Casing Hammer		No		Z Z-CLAY & GRAVEL Surface 25	
						No Reverse Rotary		No		C C-CLAY 25 31	
						No Cable-tool Bit ___ in. dia...		No		Y Y-SAND & GRAVEL 31 39	
						No Dual Rotary		No			
						No Temp. Outer Casing ___ in. dia		No			
						No Removed? ___ depth ft. (If NO explain on back side)		No			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level	
6		STEEL 18.97 LBS/FT WHEATLAND WELDED				Surface		36		1 ft. below ground surface	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is	
4		SS ALLOY MACHINE 15 SLOT				36		39		15 in. above grade	
7. Grout or Other Sealing Material											
Method MOUNDED GRANULAR BENTONITE											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test	
GRANULAR BENTONITE				Surface		36		4 S		Developed ? Yes	
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
SB				Lic # 3570		Date Signed 02-20-2026					
Drill Rig Operator				Lic or Reg #		Date Signed					
SB				7323		02-20-2026					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		75	POWTS dispersal component (soil absorption unit or mound)		95

Comment:

Created On: 02-20-2026

Updated On: 03-20-2026

Review Status: APPROVED