Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL807

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCANDINAVIAN LOG	Phone #: (715)561-5420
Mailing Address: 7020W US 2	
City: HURLEY	State: WI — Zip Code: 54534

County	Co. Permit #	Notification #	Completed
Iron		10130292101	02-13-2026

Well Constructor (Business Name): BINZ, STEVE E	Lic. #: 3570
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: BINZ BROTHERS WELL DRILLING 6400 ODANAH RD HURLEY WI 54534-9736	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity: 1	

3. Well serves 1 # of HOME
Private,potable — Borehole
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of OMA

Fire # (if avail.): 8316N

Street Address or Road Name and Number: PARDEE LAKE RD WEST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
46.2781 °N	-89.9401 °W			GPS008

NE SW or Govt Lot #	Section	Township	Range
	24	44 N	4 E

2. Well Type New Well
of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	39

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Z	Z-CLAY & GRAVEL	Surface	25
C	C-CLAY	25	31
Y	Y-SAND & GRAVEL	31	39

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 LBS/FT WHEATLAND WELDED	Surface	36
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	SS ALLOY MACHINE 15 SLOT	36	39

7. Grout or Other Sealing Material

Method: MOUNDED GRANULAR BENTONITE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	36	4 S

9. Static Water Level

1 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface
Pumping at 30 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is

15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
SB	3570	02-20-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
SB	7323	02-20-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		75	POWTS dispersal component (soil absorption unit or mound)		95

Comment:

Created On: 02-20-2026 Updated On: 03-20-2026 Review Status: APPROVED