Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL824

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: HERITAGE HILL NURSERY	Phone #
Mailing Address: 10801 PLEASANT VALLEY RD.	
City: CEDARBURG	State: WI — Zip Code: 53012
County: Ozaukee	Co. Permit #: — Notification #: 10057267101 — Completed: 02-20-2026

1. Well Location
Town of CEDARBURG
Fire # (if avail.)
Street Address or Road Name and Number: 10801 PLEASANT VALLEY ROAD
Subdivision Name: — Lot #: — Block #:
43.35048471997764, -88.04582545638513

Well Constructor (Business Name): GROTH WATER WELLS INC	Lic. #: 639
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: W69 N949 WASHINGTON AVE CEDARBURG WI 53012	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.5	

Latitude / Longitude in Decimal Degree (DD): 43.35048 °N -88.04583 °W
Method Code: SCR002

NE	NE	Section	Township	Range
or Govt Lot #		7	10 N	21 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?

3. Well serves 1 # of NURSERY
Private,potable — Drillhole
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No
Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	50
6	50	305

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	Yes
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y		H	S	Y-YELLOW H-SHALE S-SANDY	Surface	32
I		L		I-WHITE L-LIMESTONE/DOLOMITE	32	80
I	W	L		I-WHITE W-WATER BEARING L-LIMESTONE/DOLOMITE	80	305

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97# ASTM A-53 NUCOR P.E.	Surface	50
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method HALLIBURTON (SINGLE PLUG)

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	50	7 S

9. Static Water Level	11. Well Is
9 ft. below ground surface	24 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 80 ft. below surface	Disinfected ? Yes
Pumping at 37 GP M for 2 Hrs.	Capped ? Yes
Pumping Method ? Airlift	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJG	8682	04-06-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 02-23-2026 Updated On: 10-15-2026 Review Status: APPROVED