

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL835		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SWANSON, DAVE						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 1039 HEATHER DR						Town of ST. JOSEPH						464					
City WOODBURY						State MN		Zip Code MN				Street Address or Road Name and Number					
146TH AVE						Subdivision Name				Lot #		Block #					
County St. Croix		Co. Permit #		Notification # 10155412301		Completed 02-26-2026		Latitude / Longitude in Decimal Degree (DD)				Method Code					
Well Constructor (Business Name) PELKE PLBG & WELL DRLG INC						Lic. # 535		Facility ID # (Public Wells)				45.07362 °N -92.70221 °W		GPS008			
Address N6298 STATE HWY 25 DURAND WI 54736-9105						Well Plan Approval #		SE NE		Section 20		Township 30 N		Range 19 W			
								or Govt Lot #		20		30 N		19 W			
Approval Date (mm-dd-yyyy)						2. Well Type New Well											
Hicap Permanent Well #						Common Well #		Specific Capacity 0.2		of previous unique well #				constructed in			
Reason for replaced or reconstructed well ?						Reason for replaced or reconstructed well ?											
3. Well serves 1 # of HOME						Hicap Well ? No		Construction Type Drilled									
Private, potable Drillhole						Hicap Property ? No											
Heat Exchange ___ # of drillholes						Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		260		No Rotary - Mud Circulation		No		Y		Y-SAND & GRAVEL		Surface		90	
						No Rotary - Air		No		X		X-SAND & CLAY		90		175	
						No Rotary - Air & Foam		No		Y		Y-SAND & GRAVEL		175		220	
						No Drill-Through Casing Hammer				N		N-SANDSTONE		220		260	
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						Yes Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		110 ft. below ground surface				11. Well Is			
6		18.97 LBS WHEATLAND USA A-53 GR-B				Surface		220		10. Pump Test				18 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 220 ft. below surface				Developed ? Yes			
										Pumping at 20 GP M for 1 Hrs.				Disinfected ? Yes			
										Pumping Method ? Airlift				Capped ? Yes			
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No					
Method MOUNDED																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				No			
GRANULAR BENTONITE				Surface													
13. Constructor / Supervisory Driller												Lic #		Date Signed			
BP												8725		03-03-2026			
Drill Rig Operator												Lic or Reg #		Date Signed			
BP												8725		03-03-2026			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 02-24-2026

Updated On: 04-06-2026

Review Status: APPROVED