Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL886

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WEIBEL DOUG	Phone #
Mailing Address: 8401 IDYLLVIEW AVE.	
City: SPARTA	State: WI — Zip Code: 54656
County: Monroe	Co. Permit #: — Notification #: 10120506701 — Completed: 01-28-2026
Well Constructor (Business Name): LYSAKER, TIMOTHY M	Lic. #: 6199 — Facility ID # (Public Wells):
Address: TIM LYSAKER WELL DRLG & PUMP SERV LLC N7912 BLUFFVIEW CT HOLMEN WI 54636	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.2

1. Well Location

Town of SPARTA	Fire # (if avail.): 8401
Street Address or Road Name and Number: 8401 IDYLLVIEW AVE.	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.91224 °N -90.82115 °W	Method Code: SCR002
NE NW or Govt Lot #:	Section: 35 — Township: 17 N — Range: 4 W

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	16
8.75	16	63
6	63	105

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 16depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S		T-TAN/BROWN Q-CAVING S-SAND	Surface	5
T	V	N		T-TAN/BROWN V-NON-CAVING N-SANDSTONE	5	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK P.E. STEEL .280 WALL 18.97 # ASTM A53 B WHEATLAND	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

55 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 12 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	63	21 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TL	6199	01-28-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		50	POWTS dispersal component (soil absorption unit or mound)		100
			Building Drain - Sanitary		31

Comment:

Created On: 02-26-2026 Updated On: 10-15-2026 Review Status: APPROVED