

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL912		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner CHARLES HOFF						Phone # (920)766-9077		1. Well Location				Fire # (if avail.)		
Mailing Address W10257 LITZEN DR						Town of RED SPRINGS						Street Address or Road Name and Number W10257 LITZEN DR		
City GRESHAM			State WI		Zip Code 54128		Subdivision Name				Lot #		Block #	
County Shawano		Co. Permit #		Notification #		Completed 02-27-2026		Latitude / Longitude in Decimal Degree (DD) 44.9314 °N -88.7646 °W				Method Code GPS008		
Well Constructor (Business Name) DREWS WELL DRILLING INC				Lic. # 5900		Facility ID # (Public Wells)		SW SE Section Township Range or Govt Lot # 2 28 N 14 E		2. Well Type Reconstruction				
Address 170001 RINGLE AVE RINGLE WI 54471				Well Plan Approval #		Approval Date (mm-dd-yyyy)		of previous unique well # ACL798 constructed in 2026						
Hicap Permanent Well #			Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ? LOW YIELD							
3. Well serves # of HOME				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled						
Private,potable				Hicap Potable ? No										
Heat Exchange ___ # of drillholes														
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology					
8.75 Surface 40			Yes Rotary - Mud Circulation			No			Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)					
6 40 303			No Rotary - Air			No			T N S T-TAN/BROWN N-FINE S-SAND Surface 14					
			No Rotary - Air & Foam			Yes			U H Q U-BLUE H-HARD/FIRM Q-GRANITE 14 303					
			No Drill-Through Casing Hammer											
			No Reverse Rotary											
			No Cable-tool Bit ___ in. dia...			No								
			No Dual Rotary			No								
			No Temp. Outer Casing ___ in. dia											
			No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is				
6		WHEATLAND A53B 18.97LBS/FT WELDED				Surface		40		24 in. above grade				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes				
										Disinfected ? Yes				
										Capped ? Yes				
7. Grout or Other Sealing Material														
Method TREMIE PIPE - PUMPED														
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Yes					
NEAT CEMENT GROUT			Surface		40		6 S		Filled & Sealed Well(s) as needed? Yes					
PUMP INSTALLER TO DO														
13. Constructor / Supervisory Driller						Lic #		Date Signed						
EJD						5686		03-08-2026						
Drill Rig Operator						Lic or Reg #		Date Signed						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	25	POWTS holding component (also known as holding tank)	>	25

Comment:

MEASUREMENTS AND DESCRIPTIONS TAKEN FROM CONSTRUCTION REPORT FOR ACL798, DRILLED BY ARNESON WELL DRILLING. WE ONLY HYDRO-FRACTURED IT. A SINGLE PACKER WAS USED SET AT (3) DIFFERENT LEVELS.

Rehab Type	Rehab Date	Result Text
Hydrofracture	02/27/2026	YIELD BEFORE = 1GPM / AFTER = 6GPM

Created On: 02-27-2026

Updated On: 06-22-2026

Review Status: APPROVED