Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: ACL912

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CHARLES HOFF	Phone #: (920)766-9077
Mailing Address: W10257 LITZEN DR	
City: GRESHAM	State: WI — Zip Code: 54128
County: Shawano	Co. Permit #: — Notification #: — Completed: 02-27-2026
Well Constructor (Business Name): DREWS WELL DRILLING INC	Lic. #: 5900 — Facility ID # (Public Wells):
Address: 170001 RINGLE AVE, RINGLE WI 54471	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0

1. Well Location

Town of RED SPRINGS

Fire # (if avail.):

Street Address or Road Name and Number: W10257 LITZEN DR

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 44.9314 °N -88.7646 °W — Method Code: GPS008

SW	SE	Section	Township	Range
or Govt Lot #		2	28 N	14 E

2. Well Type Reconstruction

of previous unique well # ACL798 constructed in 2026

Reason for replaced or reconstructed well ?

LOW YIELD

Construction Type: Drilled

3. Well serves # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	40
6	40	303

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	N	S		T-TAN/BROWN N-FINE S-SAND	Surface	14
U	H	Q		U-BLUE H-HARD/FIRM Q-GRANITE	14	303

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A53B 18.97LBS/FT WELDED	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	40	6 S

9. Static Water Level

2 ft. below ground surface

10. Pump Test

Pumping level 250 ft. below surface

Pumping at 6 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

PUMP INSTALLER TO DO

13. Constructor / Supervisory Driller	Lic #	Date Signed
EJD	5686	03-08-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	25	POWTS holding component (also known as holding tank)	>	25

Comment: MEASUREMENTS AND DESCRIPTIONS TAKEN FROM CONSTRUCTION REPORT FOR ACL798, DRILLED BY ARNESON WELL DRILLING. WE ONLY HYDRO-FRACTURED IT. A SINGLE PACKER WAS USED SET AT (3) DIFFERENT LEVELS.

Rehab Type	Rehab Date	Result Text
Hydrofracture	02/27/2026	YIELD BEFORE = 1GPM / AFTER = 6GPM

Created On: 02-27-2026 Updated On: 06-22-2026 Review Status: APPROVED