Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL920

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WILLIAM ROTH	Phone #
Mailing Address: 689 140 ST	
City: ROBERTS	State: WI — Zip Code: 54023
County: St. Croix	Co. Permit #: — Notification #: 10141904402 — Completed: 02-24-2026
Well Constructor (Business Name): STEVE'S WELL AND PUMP SERVICES, LLC	Lic. #: 8260 — Facility ID # (Public Wells):
Address: 499 192ND AVE SOMERSET WI 54025	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5

1. Well Location

Town of WARREN				Fire # (if avail.): 689
Street Address or Road Name and Number: 140 ST				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 44.96293 °N -92.517 °W				Method Code: SCR002
NW NW or Govt Lot #	Section: 36	Township: 29 N	Range: 18 W	

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	60
6	60	120

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	C		T-TAN/BROWN V-NON-CAVING C-CLAY	Surface	23
Y	H	L		Y-YELLOW H-HARD/FIRM L-LIMESTONE/DOLOMITE	23	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NUCORE 18.99 LBS FT WELDED ASTM	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	60	30 S

9. Static Water Level
58 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
SF	6412	02-28-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		85	POWTS dispersal component (soil absorption unit or mound)		105

Comment:

Created On: 02-28-2026 Updated On: 10-15-2026 Review Status: APPROVED