Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL923

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: OLSEN TRUST			Phone #
Mailing Address: 2218 HILLINGTON GREEN			
City: MADISON	State: WI	Zip Code: 53726	
County: Door	Co. Permit #:	Notification #: 10156622001	Completed: 03-02-2026

Well Constructor (Business Name): RETZLAFF & GREGORICH	Lic. #: 7267	Facility ID # (Public Wells):	
Address: WELL DRILLING LLC 5861 MARY'S RD NEW FRANKEN WI 54229		Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.7	

1. Well Location

Town of GIBRALTAR				Fire # (if avail.): 3862
Street Address or Road Name and Number: CTY RD F				
Subdivision Name:	Lot #:	Block #:		
Latitude / Longitude in Decimal Degree (DD): 45.12486 °N -87.22499 °W				Method Code: GPS008
NE / NW or Govt Lot #:	Section: 33	Township: 31 N	Range: 27 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable Drillhole
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	9
8	9	171
6	171	203

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 9depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Z	Z	Z-CLAY & GRAVEL Z-W/COBBLES/BOULDERS	Surface	5
		L		L-LIMESTONE/DOLOMITE	5	203

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	MAUICHI LEAVITT ASTM A53B 6.625IN X 0.280IN PE WELDED JOINT MADE IN USA	Surface	173
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
50 ft. below ground surface

10. Pump Test
Pumping level 120 ft. below surface
Pumping at 50 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT PORTLAND CEMENT	Surface	171	87 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
KG	6985	03-02-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Collector - Sanitary		150

Comment:

Created On: 03-02-2026 Updated On: 04-21-2026 Review Status: APPROVED