Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL933

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ANDERSON KATHRYN	Phone #
Mailing Address: 12676 W COUNTY HWY B	
City: HAYWARD	State: WI — Zip Code: 54843
County: Sawyer	Co. Permit #: — Notification #: 10142853601 — Completed: 03-02-2026
Well Constructor (Business Name): FROEMEL WELL	Lic. #: 6080 — Facility ID # (Public Wells):
Address: 15251 W COUNTY B, HAYWARD WI 54843-4100	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.6

1. Well Location

Town of HAYWARD	Fire # (if avail.): 12676 W
Street Address or Road Name and Number: COUNTY HWY B	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.99212 °N -91.32572 °W	Method Code: GPS008
SE NE or Govt Lot #:	Section: 35 — Township: 41 N — Range: 8 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	72

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	S	S		S-SOFT/LOOSE S-SAND	Surface	20
		S	M	S-SAND M-SILTY	20	40
	W	Y	D	W-WATER BEARING Y-SAND & GRAVEL D-W/GLACIAL MATERIAL	40	60
	W	Y		W-WATER BEARING Y-SAND & GRAVEL	60	72

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCA WEILDED ASTM A53B 18.97LB/FT	Surface	69
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	15 SLOT SS	69	72

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 46 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
22 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TF	7401	03-02-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		80	POWTS dispersal component (soil absorption unit or mound)		85

Comment:

Created On: 03-02-2026 Updated On: 03-31-2026 Review Status: APPROVED