Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL941

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DYE, DON	Phone #: (608)359-0013
Mailing Address: N4483 COUNTY ROAD F	
City: BRODHEAD	State: WI — Zip Code: 53520

County	Co. Permit #	Notification #	Completed
Green	25-87	10096665101	02-11-2026

Well Constructor (Business Name): BLOYER WELL & PUMP CO INC	Lic. #: 87
Address: 14312 FULMAR DR SOUTH BELOIT IL 61080-2399	

Facility ID # (Public Wells)		
Well Plan Approval #		
Approval Date (mm-dd-yyyy)		

Hicap Permanent Well #	Common Well #	Specific Capacity
	02	2.5

3. Well serves # of POLE BARN
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of DECATUR	Fire # (if avail.): N4483

Street Address or Road Name and Number: N4483 COUNTY ROAD F BRODHEAD WI 53520

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
42.66748 °N -89.44959 °W	SCR002

NE NE or Govt Lot #	Section	Township	Range
	8	2 N	9 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	60
6	60	280

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		C		T-TAN/BROWN C-CLAY	Surface	6
T	B	N		T-TAN/BROWN B-BROKEN N-SANDSTONE	6	41
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	41	81
G		L		G-GRAY L-LIMESTONE/DOLOMITE	81	118
		N	L	N-SANDSTONE L-LIMEY OR DOLOMITIC	118	167
T		L		T-TAN/BROWN L-LIMESTONE/DOLOMITE	167	262
T		N		T-TAN/BROWN N-SANDSTONE	262	280

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLK T&C STEEL .280 #19.45 ASTM A53 WHEATLAND USA	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	60	17 S

9. Static Water Level	11. Well Is
199 ft. below ground surface	12 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 205 ft. below surface	Disinfected ? Yes
Pumping at 15 GP M for 1.5 Hrs.	Capped ? Yes
Pumping Method ? Airlift	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
AES	6639	03-02-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		325	POWTS dispersal component (soil absorption unit or mound)		334

Comment:

Created On: 03-02-2026 Updated On: 10-15-2026 Review Status: APPROVED