

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL941		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner DYE, DON						Phone # (608)359-0013					
Mailing Address N4483 COUNTY ROAD F											
City BROADHEAD				State WI		Zip Code 53520					
County Green		Co. Permit # 25-87		Notification # 10096665101		Completed 02-11-2026					
Well Constructor (Business Name) BLOYER WELL & PUMP CO INC						Lic. # 87		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.66748 °N -89.44959 °W	
Address 14312 FULMAR DR SOUTH BELOIT IL 61080-2399						Well Plan Approval #		NE NE Section Township Range or Govt Lot # 8 2 N 9 E		Method Code SCR002	
						Approval Date (mm-dd-yyyy)					
Hicap Permanent Well #		Common Well # 02		Specific Capacity 0		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
3. Well serves # of POLE BARN Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology		
10 Surface 60			No Rotary - Mud Circulation No			T C T-TAN/BROWN C-CLAY Surface 6					
6 60 280			No Rotary - Air No			T B N T-TAN/BROWN B-BROKEN N-SANDSTONE 6 41					
			Yes Rotary - Air & Foam Yes			T H N T-TAN/BROWN H-HARD/FIRM N-SANDSTONE 41 81					
			No Drill-Through Casing Hammer			G L G-GRAY L-LIMESTONE/DOLOMITE 81 118					
			No Reverse Rotary			N L N-SANDSTONE L-LIMEY OR DOLOMITIC 118 167					
			No Cable-tool Bit ___ in. dia... No			T L T-TAN/BROWN L-LIMESTONE/DOLOMITE 167 262					
			No Dual Rotary No			T N T-TAN/BROWN N-SANDSTONE 262 280					
			No Temp. Outer Casing ___ in. dia								
			No Removed? ___ depth ft. (If NO explain on back side)								
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6		BLK T&C STEEL .280 #19.45 ASTM A53 WHEATLAND USA				Surface		60			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material											
Method TREMIE PIPE - PUMPED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
NEAT CEMENT GROUT		Surface		60		17 S					

9. Static Water Level

199 ft. below ground surface

10. Pump Test

Pumping level 205 ft. below surface

Pumping at 15 GP M for 1.5 Hrs.

Pumping Method ? Airlift

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

AES

6639

03-02-2026

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		325	POWTS dispersal component (soil absorption unit or mound)		334

Comment:

Created On: 03-02-2026

Updated On: 03-27-2026

Review Status: APPROVED