Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL947

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	RINEHART, MARY
Phone #	
Mailing Address	N5848 LAKEVIEW CT W
City	ONALASKA
State	WI
Zip Code	54650

County	Co. Permit #	Notification #	Completed
La Crosse	2025080	9981134302	08-23-2025

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
LYSAKER, DAVID LLOYD	8130	

Address 11982 SOUTH ST
TREMPEALEAU WI 54661

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.3

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of ONALASKA

Fire # (if avail.) N5848

Street Address or Road Name and Number
N5848 LAKEVIEW CT W

Subdivision Name	Lot #	Block #
LAKEVIEW ADD	12	2

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.9321 °N	-91.302 °W			SCR002

NE	SW	Section	Township	Range
or Govt Lot #		23	17 N	8 W

2. Well Type Replacement
of previous unique well # FQ654 constructed in 1992

Reason for replaced or reconstructed well ?
WATER SUPPLY

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	105

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Y	T-TAN/BROWN Y-SAND & GRAVEL	Surface	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW P.E. BLACK STEEL, .237WALL, 10.79#, ASTM A53B, WHEATLAND, WELDED	Surface	102
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3.5	.15SLOT CONT. STAINLESS STEEL	102	105

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	102	2 S

9. Static Water Level
28 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 15 GP M for 12 Hrs.
Pumping Method ? Test Pump

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DL	8130	08-23-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		45
POWTS dispersal component (soil absorption unit or mound)		65
Building Drain - Sanitary		25
Sewer - Building Sanitary		40

Comment:

Created On: 03-03-2026 Updated On: 10-15-2026 Review Status: APPROVED