

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL967		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner KLITGAURD DANIEL						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 344 95 ST						Town of BLACK BROOK						344	
City CLEAR LAKE						State WI		Zip Code 54005				Street Address or Road Name and Number	
95 ST						Subdivision Name				Lot #		Block #	
County Polk		Co. Permit #		Notification # 10157092401		Completed 03-03-2026		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name) STEVE'S WELL AND PUMP SERVICES, LLC				Lic. # 8260		Facility ID # (Public Wells)				45.25853 °N -92.35628 °W		SCR002	
Address 499 192ND AVE SOMERSET WI 54025				Well Plan Approval #		NW SE		Section 16		Township 32 N		Range 16 W	
				Approval Date (mm-dd-yyyy)		or Govt Lot #		16		32 N		16 W	
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type Replacement				of previous unique well # constructed in			
Reason for replaced or reconstructed well ?		LACK OF WATER											
3. Well serves 1 # of HOME						Hicap Well ? No		Construction Type Drilled					
Private, potable						Hicap Property ? No							
Heat Exchange ___ # of drillholes						Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
6		Surface		180		No Rotary - Mud Circulation				No			
						No Rotary - Air				Yes			
						No Rotary - Air & Foam				No			
						Yes Drill-Through Casing Hammer							
						No Reverse Rotary							
						No Cable-tool Bit ___ in. dia...				No			
						No Dual Rotary				No			
						No Temp. Outer Casing ___ in. dia							
						No Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
T		X		C		T-TAN/BROWN X-LENSED/STREAKED/LAYERED C-CLAY				Surface		35	
T		S		S		T-TAN/BROWN S-SOFT/LOOSE S-SAND				35		60	
G		V		C		G-GRAY V-NON-CAVING C-CLAY				60		165	
Y		H		L		Y-YELLOW H-HARD/FIRM L-LIMESTONE/DOLOMITE				165		180	
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		NUCORE 18.99 LBS FT WELDED ASTM				Surface		168					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE				Surface		168		6 S					
9. Static Water Level													
115 ft. below ground surface													
10. Pump Test													
Pumping level 170 ft. below surface													
Pumping at 10 GP M for 1 Hrs.													
Pumping Method ? Airlift													
11. Well Is													
16 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? Yes													
OTHER COMPANY TO DO													
Filled & Sealed Well(s) as needed? Yes													
OTHER COMPANY TO DO													
13. Constructor / Supervisory Driller				Lic #		Date Signed							
SF				6412		03-03-2026							
Drill Rig Operator				Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		45

Comment:

Created On: 03-03-2026

Updated On: 03-27-2026

Review Status: APPROVED