Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL967

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KLITGAURD DANIEL	Phone #
Mailing Address: 344 95 ST	
City: CLEAR LAKE	State: WI — Zip Code: 54005
County: Polk	Co. Permit #: — Notification #: 10157092401 — Completed: 03-03-2026
Well Constructor (Business Name): STEVE'S WELL AND PUMP SERVICES, LLC	Lic. #: 8260 — Facility ID # (Public Wells):
Address: 499 192ND AVE, SOMERSET WI 54025	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.2

1. Well Location

Town of BLACK BROOK	Fire # (if avail.): 344
Street Address or Road Name and Number: 95 ST	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.25853 °N -92.35628 °W	Method Code: SCR002
NW SE or Govt Lot #:	Section: 16 — Township: 32 N — Range: 16 W

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: LACK OF WATER

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	180

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	X	C		T-TAN/BROWN X-LENSED/STREAKED/LAYERED C-CLAY	Surface	35
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	35	60
G	V	C		G-GRAY V-NON-CAVING C-CLAY	60	165
Y	H	L		Y-YELLOW H-HARD/FIRM L-LIMESTONE/DOLOMITE	165	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NUCORE 18.99 LBS FT WELDED ASTM	Surface	168
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	168	6 S

9. Static Water Level

115 ft. below ground surface

10. Pump Test

Pumping level 170 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

16 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

OTHER COMPANY TO DO

Filled & Sealed Well(s) as needed? Yes

OTHER COMPANY TO DO

13. Constructor / Supervisory Driller	Lic #	Date Signed
SF	6412	03-03-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		45

Comment:

Created On: 03-03-2026 Updated On: 10-15-2026 Review Status: APPROVED