

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL991		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner STEELE, JASON						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address S3539 A OLD HWY 14						Town of VIROQUA						S3539 A					
City VIROQUA						State WI		Zip Code 54665				Street Address or Road Name and Number OLD HWY 14					
County Vernon		Co. Permit #		Notification # 10156930901		Completed 03-03-2026		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) SCHAITELE, JAKE J				Lic. # 3822		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.6025 °N -90.8854 °W				Method Code SCR002			
Address TRI COUNTY WELL DRILLING 8301 IDOL AVE SPARTA WI 54656-5603				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 17 13 N 4 W		2. Well Type New Well				of previous unique well # constructed in					
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2				Reason for replaced or reconstructed well ?							
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable				Hicap Property ? No							
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology								
10 Surface 180			No Rotary - Mud Circulation No			R V C R-RED V-NON-CAVING C-CLAY Surface 13											
6 180 240			No Rotary - Air No			T S N T-TAN/BROWN S-SOFT/LOOSE N-SANDSTONE 13 49											
			Yes Rotary - Air & Foam Yes			T H L T-TAN/BROWN H-HARD/FIRM L-LIMESTONE/DOLOMITE 49 240											
			No Drill-Through Casing Hammer														
			No Reverse Rotary														
			No Cable-tool Bit ___ in. dia... No														
			No Dual Rotary No														
			No Temp. Outer Casing ___ in. dia														
			No Removed? ___ depth ft. (If NO explain on back side)														
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is					
6		NEW PE BLACK STEEL ASTMA 53 18.95 280 WALL WELD USA NTP				Surface		180		119 ft. below ground surface		21 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes					
										Pumping level 200 ft. below surface		Disinfected ? Yes					
										Pumping at 15 GP M for 3 Hrs.		Capped ? Yes					
										Pumping Method ? Airlift							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No					
Method TREMIE PIPE - PUMPED																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
NEAT CEMENT GROUT				Surface		180		112 S									
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												JS		3822		03-04-2026	
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 03-04-2026

Updated On: 03-27-2026

Review Status: APPROVED