Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL991

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STEELE, JASON	Phone #
Mailing Address: S3539 A OLD HWY 14	
City: VIROQUA	State: WI — Zip Code: 54665
County: Vernon	Co. Permit #: — Notification #: 10156930901 — Completed: 03-03-2026
Well Constructor (Business Name): SCHAITEL, JAKE J	Lic. #: 3822 — Facility ID # (Public Wells):
Address: TRI COUNTY WELL DRILLING 8301 IDOL AVE SPARTA WI 54656-5603	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.2

1. Well Location

Town of VIROQUA	Fire # (if avail.): S3539 A
Street Address or Road Name and Number: OLD HWY 14	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.6025 °N -90.8854 °W	Method Code: SCR002
NW SW or Govt Lot #:	Section: 17 — Township: 13 N — Range: 4 W

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	180
6	180	240

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	V	C		R-RED V-NON-CAVING C-CLAY	Surface	13
T	S	N		T-TAN/BROWN S-SOFT/LOOSE N-SANDSTONE	13	49
T	H	L		T-TAN/BROWN H-HARD/FIRM L-LIMESTONE/DOLOMITE	49	240

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PE BLACK STEEL ASTMA 53 18.95 280 WALL WELD USA NTP	Surface	180
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

119 ft. below ground surface

10. Pump Test

Pumping level 200 ft. below surface

Pumping at 15 GP M for 3 Hrs.

Pumping Method ? Airlift

11. Well Is

21 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	180	112 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JS	3822	03-04-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 03-04-2026 Updated On: 08-18-2026 Review Status: APPROVED