

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACL993		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner HOOVER, MAYNARD						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 213901 MARCH RAPIDS AVE						Town of EAU PLEINE						213901					
City STRATFORD						State WI		Zip Code 54484				Street Address or Road Name and Number MARCH RAPIDS AVE					
County Marathon		Co. Permit #		Notification # 10160435701		Completed 03-03-2026		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) HAUPT WELL DRLG INC				Lic. # 6602		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.8104 °N -90.1493 °W			Method Code GPS008						
Address PO BOX 136 AUBURNDALE WI 54412				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 21 27 N 3 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NON-COMPLYING									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 16		Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled									
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes																	
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8.75		Surface		9		<u>No</u> Rotary - Mud Circulation		<u>No</u>		C		C-CLAY		Surface		16	
8		9		40		<u>Yes</u> Rotary - Air		<u>Yes</u>		D Q		D-DECOMPOSED/WEATHERED Q-GRANITE		16		34	
6		40		160		<u>No</u> Rotary - Air & Foam		<u>No</u>		Q		Q-GRANITE		34		160	
						<u>No</u> Drill-Through Casing Hammer											
						<u>No</u> Reverse Rotary											
						<u>No</u> Cable-tool Bit ___ in. dia...		<u>No</u>									
						<u>No</u> Dual Rotary		<u>No</u>									
						<u>Yes</u> Temp. Outer Casing 8in. dia											
						<u>Yes</u> Removed? 9depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		34 ft. below ground surface				23 in. above grade			
6		ASTM A53B-280 WALL WELDED-MADE WHEATLAND TUBE				Surface		40		10. Pump Test				Developed ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 35 ft. below surface				Disinfected ? Yes			
										Pumping at 16 GP M for 1 Hrs.				Capped ? Yes			
										Pumping Method ? Test Pump							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No					
Method PRESSURE DISPLACEMENT												DNR TO USE NON-COMPLYING WELL AS MONITORING WELL AND TO BE ABANDONED AT A LATER DATE					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
NEAT CEMENT				Surface		40		6 S		DNR TO USE NON-COMPLYING WELL AS MONITORING WELL AND TO BE ABANDONED AT A LATER DATE							
												13. Constructor / Supervisory Driller					
												Lic #		Date Signed			
												6634		03-11-2026			
Drill Rig Operator												Lic or Reg #		Date Signed			
SH												6634		03-11-2026			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	300	Septic or Holding, or POWTS Tank	=	220

Comment:

Created On: 03-04-2026

Updated On: 04-16-2026

Review Status: APPROVED