Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACL998

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: OSADJAN, KEVIN	Phone #
Mailing Address: P.O. BOX 106	
City: TOWNSEND	State: WI — Zip Code: 54175
County: Oconto	Co. Permit #: 10009790801 — Notification #: 10009790801 — Completed: 02-25-2026
Well Constructor (Business Name): MAIDEN LAKE PLUMBING LLC	Lic. #: 8305 — Facility ID # (Public Wells)
Address: 15003 STATE HWY 32 LAKEWOOD WI 54138	Well Plan Approval # / Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity: 1.3

1. Well Location

Town of TOWNSEND	Fire # (if avail.): 18757
Street Address or Road Name and Number: ASHLEY COURT	
Subdivision Name	Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): 45.3568 °N -88.5844 °W	Method Code: GPS008
SW NE or Govt Lot #	Section: 11 — Township: 33 N — Range: 15 E

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Driven Point

3. Well serves 1 # of GARAGE
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	50

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND GALV, ASTM A53, 300 PSI, THREADED ENDS WITH DRIVE COUPLINGS	Surface	47
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	MIDWEST 60 GAZ	47	50

7. Grout or Other Sealing Material
Method

8. Geology

9. Static Water Level
14 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 8 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
NP	8119	03-04-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 03-04-2026 Updated On: 06-24-2026 Review Status: APPROVED