Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM007

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WAVRUNEK QUINTEN	Phone #: (920)255-2650
Mailing Address: 4166 TOWNLINE RD	
City: KEWAUNEE	State: WI — Zip Code: 54216
County: Kewaunee	Co. Permit #:
Notification #: 10161150701	Completed: 03-04-2026
Well Constructor (Business Name): RETZLAFF & GREGORICH	Lic. #: 7267
Facility ID # (Public Wells):	
Address: WELL DRILLING LLC 5861 MARY'S RD NEW FRANKEN WI 54229	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.4	

1. Well Location

Town of WEST KEWAUNEE	Fire # (if avail.): E4116
Street Address or Road Name and Number: TOWNLINE RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.4148 °N -87.56181 °W	Method Code: GPS008
SW SW or Govt Lot #:	Section: 35 — Township: 23 N — Range: 24 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of SHOP LIVING QUARTERS

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	121
6	121	143

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K		I		K-BLACK I-SOIL-ORGANIC	Surface	1
		X		X-SAND & CLAY	1	6
		C		C-CLAY	6	86
		G		G-GRAVEL/STONES	86	102
		Z		Z-CLAY & GRAVEL	102	119
	B	L		B-BROKEN L-LIMESTONE/DOLOMITE	119	120
I		L		I-WHITE L-LIMESTONE/DOLOMITE	120	143

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	MARUICHI LEAVITT ASTM A53B 6.625IN X 0.280IN PE WELDED JOINT MADE IN USA	Surface	123
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

63 ft. below ground surface

10. Pump Test

Pumping level 100 ft. below surface

Pumping at 50 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

16 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BAROIDE 20% HIGH SOLIDS BENTONITE	Surface	121	12 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
KG	6985	03-04-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		110	Septic or Holding, or POWTS Tank		110

Comment:

Created On: 03-04-2026 Updated On: 04-21-2026 Review Status: APPROVED