

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM009		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner CLARK, LAURA					Phone # (715)874-6789			1. Well Location				Fire # (if avail.)				
Mailing Address N3809 790TH STREET								Town of SPRING BROOK				N3662				
City ELK MOUND					State WI		Zip Code 54739		Street Address or Road Name and Number 750TH STREET							
County Dunn		Co. Permit # 2601210		Notification # 10160498501		Completed 03-03-2026		Subdivision Name				Lot #		Block #		
Well Constructor (Business Name) J & K PUMP & WELL SERVICE					Lic. # 8364		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.8125 °N -91.7815 °W				Method Code GPS008			
Address 20458 80TH AVE CADOTT WI 03					Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW NE		Section 24		Township 27 N		Range 12 W	
									or Govt Lot #							
Hicap Permanent Well #			Common Well #		Specific Capacity 5		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
3. Well serves 1 # of HOME					Hicap Well ? No											
Private, potable					Hicap Property ? No											
Heat Exchange ___ # of drillholes					Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method																
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock						
6		Surface		65		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>Yes</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)										
8. Geology																
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND				Surface		32						
T	V	X		T-TAN/BROWN V-NON-CAVING X-SAND & CLAY				32		42						
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE				42		65						
6. Casing, Liner, Screen																
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)								
6		NEW STEEL THREADED AND CUPPLED 20 LBS PER FT ASTM A 53 B 1800 PSI WHEATLAND PIPE				Surface		42								
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)								
7. Grout or Other Sealing Material																
Method MOUNDED																
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement								
GRANULAR BENTONITE				Surface				1 S								
9. Static Water Level																
8 ft. below ground surface																
10. Pump Test																
Pumping level 10 ft. below surface Pumping at 10 GP M for 2 Hrs. Pumping Method ? Test Pump																
11. Well Is																
24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes																
12. Notified Owner of need to fill & seal ? No																
Filled & Sealed Well(s) as needed? No																
13. Constructor / Supervisory Driller				Lic #		Date Signed										
JK				6336		03-31-2026										
Drill Rig Operator				Lic or Reg #		Date Signed										
JK				6336		03-31-2026										

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	90	Sewer - Building Sanitary	=	50
Building Drain - Sanitary	=	32	Septic or Holding, or POWTS Tank	=	75

Comment:

Created On: 03-04-2026

Updated On: 04-24-2026

Review Status: APPROVED