Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM009

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CLARK, LAURA	Phone #: (715)874-6789
Mailing Address: N3809 790TH STREET	
City: ELK MOUND	State: WI — Zip Code: 54739
County: Dunn	Co. Permit #: 2601210 — Notification #: 10160498501 — Completed: 03-03-2026
Well Constructor (Business Name): J & K PUMP & WELL SERVICE	Lic. #: 8364 — Facility ID # (Public Wells):
Address: 20458 80TH AVE CADOTT WI 03	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 5

1. Well Location

Town of SPRING BROOK	Fire # (if avail.): N3662
Street Address or Road Name and Number: 750TH STREET	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.8125 °N -91.7815 °W	Method Code: GPS008
NW NE or Govt Lot #:	Section: 24 — Township: 27 N — Range: 12 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	65

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	Surface	32
T	V	X		T-TAN/BROWN V-NON-CAVING X-SAND & CLAY	32	42
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	42	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL THREADED AND CUPPLED 20 LBS PER FT ASTM A 53 B 1800 PSI WHEATLAND PIPE	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 10 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JK	6336	03-31-2026
Drill Rig Operator	Lic or Reg #	Date Signed
JK	6336	03-31-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	90
Building Drain - Sanitary	=	32
Sewer - Building Sanitary	=	50
Septic or Holding, or POWTS Tank	=	75

Comment:

Created On: 03-04-2026 Updated On: 04-24-2026 Review Status: APPROVED